

FAX	EMAIL	WEB	SMS
RP	SP	OP	LOCAL
e-Despatch			

Website: www.oscsc.in
Fax No.-0674-2395291
Phone No.-2395291



ODISHA STATE CIVIL SUPPLIES CORPORATION LTD.,

Plot No.C/2, Nayapalli, Bhubaneswar-751012

CIN: U51211OR1980SGC000894

(A Govt. of Odisha Undertaking)

TENDER CALL NOTICE

No: Syst/Pur/69/2017-18

7573

Dated: 05.06.20.

Sealed tenders in plain paper/letter pad are invited from the intending authorized dealers in the jurisdiction of Bhubaneswar, Odisha registered under GST Act and having PAN Number for supply of Online UPS for office use in OSCSC Ltd Head Office and District Offices. The quotation completed in all respect shall reach the undersigned by Speed Post/Registered Post/Courier superscribing the word "**TENDER PAPER FOR SUPPLY OF 3KVA ONLINE UPS**" on the envelope containing quotations & EMD. The last date of receipt of tender papers is 24/6/20 at 2.00 P.M. The tender papers shall be opened on 24/6/20 at 4.00 P.M. in the presence of tenderers or their authorized representatives in the Office chamber of the FA & CAO, OSCSC Ltd. Bhubaneswar. The tender paper shall contain a Bank Draft amounting to Rs.20000/- drawn in favor of the Managing Director., OSCSC Ltd., Bhubaneswar towards EMD. The tender papers will not be received after the specified date & time as mentioned above.

Dr.
3.6.20

Managing Director

LIST OF DOCUMENTS TO BE ATTACHED WITH THE TENDER PAPER

SL No.	BASIC REQUIREMENT	SPECIFIC REQUIREMENT	DOCUMENTS REQUIRED
1	Legal entity	The tenderer must be an authorized vendor or supplier. The tenderer must be a registered dealer under the GST Act and should have PAN Number.	-GST Registration Certificate -PAN copy -Bid Specific Authorization from the OEM
2	Local Presence of the tenderer and OEM	The tenderer should have registered office at Bhubaneshwar, Odisha. The OEM must have an existing Service centre in Odisha. Address proof required for physical verification.	Self-certified letter on existence of Local office along with necessary evidence. Address proof of OEM
3	Black Listing	Affidavit by the authorized signatory of the tenderer that the firm has not been black listed by any central/state government and public sector undertaking.	Valid Affidavit
4	EMD	The tenderer must have submitted the EMD of Rs. <u>20,000/-</u> (Twenty thousand) only.	In shape of Account payee Demand Draft from any nationalized bank drawn in favour of Managing Director, OSCSC Ltd, payable at Bhubaneswar
5	Performance Bank Guarantee (PBG)	Within 15 days of the receipt of Notification of Award / Letter of Intent from the Purchaser, the successful Bidder shall furnish the Performance Security in the form of Bank Guarantee executed on non-judicial stamp paper worth Rs.100/- (Rupees One hundred only) issued by a Public Sector Bank in favour of Managing Director, OSCSC Ltd, Bhubaneswar only for an amount of Rs 100000/- (Rupees One Lakh only).	Performance security in the form of Bank Guarantee executed on non-judicial stamp paper worth Rs.100/-
6	Proof of Testing	ISO: ISO 9001, ISO 14001, ISO 27001, OSHAS Certified	Quality Certificate from global

			consultants like DNV, TUV, SGS etc.
7	Certification	OEM should be Top 5 brand company for UPS in India.	Frost and suvillian certificate to be shared.
8	Proof of Specification	The Specification quoted in the tender paper against a specific model of any OEM should match the specification mentioned in the website of the OEM	Copy of Specification mentioned in OEM website
9	Chartered Accountant Certificate of Bidder	Bidder should have a positive net worth, in each of the last 2 audited financial year.	The audited balance sheet and Profit & loss statement of Bidder for financial year 2017-18 and 2018-2019 are to be submitted along with CA certificate as documentary evidence.
10	Experience certificate	Documents for the supply/service of similar type of products to any Govt. Deptt/PSU should be submitted.	Purchase Order/Service Order Copy

for

Quantity of the Items for which the price to be quoted

Sl no.	Item Description	Quantity
1	Online UPS 3 KVA with Batteries	10


Pr
3.6.20
Managing Director

Specification for 3KVA Online UPS

GENERAL		
1	Rating in KVA (KVA)	3.0 KVA
2	Equivalent KWH	2.4 or higher
3	Technology	IGBT-PWM without inbuilt isolation transformer
4	Input Power	Single phase 110V - 280V sinewave,50Hz
5	Output power	Single phase 230V +/-1% sinewave 50 Hz
6	Output Power Factor	0.8 or above
BATTERY		
7	Type of Battery	SMF-VRLA conforming to JISC:8702(Pt.I,II&III),
8	Backup time (Minutes)	100 Minutes or higher with full load
9	Minimum VAH (VAh)	4680 (6 Battery (12 Volts) , 65 Ah each)
10	Charging Current Capacity	16 Amps, settable 1/2/4/6/8/10/12/14/16 Amp
11	Warranty for UPS (Years)	2
12	Warranty for battery	2
13	Movable trolley for Batteries	Yes
14	Degree of Protection	IP20
15	Cabling 5 meters for input and out put	With
16	Paralleling kit for synchronising	With
17	Installation and Commissioning	Yes
FUNCTIONAL		
18	Maximum overshoot and Under shoot of output rated voltage	4
19	Voltage Regulation from no load to full load (%)	< / = 3%
20	20% Overload limit for minimum 10 minutes	Yes
21	Overall Efficiency (%)	>/=90%
22	Total Harmonic Distortion(THD) (%)	Maximum 3%
23	50% Overload limit for minimum 1 minutes	Yes
PROTECTION		
24	Protection for under voltage at battery terminal at 10.5V per 12 V battery.	Yes
25	Protection of Over voltage,Short Circuit & over load at UPS output terminal	Yes
26	High Voltage Protection	Inbuilt OVCD
METERING AND INDICATIONS		
27	Digital Metering in UPS for AC Input Voltage,Output AC Voltage,Current,Frequency,Battery Voltage and Current	Yes

Amr

28	Indicators for mains presence, Battery charging and discharging, Output Over Load, Low Battery Voltage	Yes
29	Ambient Temperature	0-50 deg C
REPORTS AND CERTIFICATION		
30	ISO: ISO 9001, ISO 14001, ISO 27001, OSHAS Certified	Yes
31	Damp Heat : in accordance with IS:9000(part 5/sec.2)1981 at Temperature of 40 degree C, two cycles of (12+12) hours each 2007)	Yes
32	Dry Heat Test : in accordance with IS:9000 (part 3/sec.5)1977 (reaffirmed 2007) at 55 degree C for 16 hrs	Yes
33	Cold Test : in accordance with IS:9000 (Part 2/Sec.4)1977 (Reaffirmed 2007) at -10 degree C for 4 hrs.	Yes
34	Availability of the Type Test Report from Central Govt. /NABL/ILAC Accredited lab covering all technical requirements.	Yes
35	As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable	Yes


 3.6.20
 Managing Director

TERMS AND CONDITIONS

- a) The tenderers shall quote the item wise price along with GST (Goods & Service Tax) chargeable separately in the quotation.
- b) A Copy of the valid GST No. & PAN should be furnished with the quotation.
- c) The tender paper without required amount of EMD and documents as mentioned will not be accepted.
- d) The Tender paper without required specification as mentioned will not be accepted.
- e) The Specification quoted in the tender paper against a specific model of any OEM should match the specification mentioned in the website of the OEM. The customized or assembled product will not be accepted.
- f) The quoted price shall be valid for 1(one) year from the date of Purchase Order/Supply of items, whichever is later & which may be extended for subsequent years on mutually agreeable conditions by both the parties.
- g) The Purchaser reserves the right to vary the quantity i.e. increase or decrease the number of materials without any change in terms and conditions at the time of placing the orders or during the execution of the Contract.
- h) The tenderers shall supply the required items as and when necessary within the stipulated time frame by the Corporation.
- i) Supply of Online UPS shall be made only as per the accepted rate and as per the order given by the Corporation from time to time.
- j) The UPS must be compatible with Li-ION Battery.
- k) The supply of intended articles shall be made available within 7 (seven) days from the date of issue of indented order.
- l) Failure to supply and installation of the total quantity of Online UPS within the stipulated time the supply order shall be cancelled along with forfeiture of EMD.
- m) The EMD amount of the successful tenderer will be kept as security for 1 Year in service support purpose.
- n) The EMD of all unsuccessful tenderers will be refunded to them on the same day with proper acknowledgment.
- o) The selected vendor may agree to deliver the items as per our requirement at the District level throughout the state at his own cost. No extra charges will be paid beyond the quoted price duly approved by the committee.
- p) The Selected vendor must provide service support for the Online UPS with no extra charge within the warranty period.

Md -

- q) In the event, any of the materials / equipment supplied by the Contractor is found defective due to faulty design, bad workmanship, bad materials used or otherwise not in conformity with the requirements of the Specification, the Purchaser shall either reject the materials / equipment or ask the Contractor in writing to rectify the same. The Contractor on receipt of such notification shall either rectify or replace the defective materials/equipment free of cost to the Purchaser.
- r) Bidder should have registered Office in the state of Odisha i.e. location of consignee registered since last 1 year from the date of publication of Tender.
- s) The OEM must have an existing Service center in Odisha. (Address proof required for physical verification).
- t) If required Proof of Concept Test of the product will be done in the premises of purchaser before finalization of the Award of Contract to the successful bidder.
- u) Within 15 days of the receipt of Notification of Award / Letter of Intent from the Purchaser, the successful Bidder shall furnish the Performance Security in the form of Bank Guarantee for an amount of Rs.100000/- (Rupees One Lakh only) executed on non-judicial stamp paper worth of Rs.100/- (Rupees One hundred only) issued by a Public Sector Bank in favour of **Managing Director, OSCSC Ltd.**
- v) Timely Servicing/rectification of defects during warranty period : After having been notified of the defects/ service requirement during warranty period, seller has to complete the required service/rectification within 10 working days time limit. If the seller fails to complete service /rectification with defined time limit, a penalty of 0.5% of Unit price of the product shall be charged as penalty for each week of delay from the seller. Seller can deposit the penalty with the Buyer. The Buyer shall have right to recover all such penalty amount from the Performance Security (PBG).
- w) In the event of any dispute arising out of this contract the jurisdiction of court shall be at Bhubaneswar for both the parties.
- x) The authority reserves the right to accept or reject any or all tender papers without assigning any reasons thereof.

DM
2-6-20

Managing Director

Memo no. 7574 dt. 05.06.20.

Copy to Notice Board of Head Office/Bill Section/Sri Sumit Kumar Batu, Asst. Programmer, IT Section, OSCSC Ltd for information and to host the same in the website of OSCSC Ltd. i.e. www.oscsc.in

Md.
3.6.20

Managing Director

Memo no. 7575 dt. 05.06.20.

Copy forwarded to Diary Section, OSCSC Ltd for information and request to receive sealed tenders "Tender Paper for Supply of 3KVA Online UPS" till dt. 24/6/20 at 2 P.M. and may be handed over immediately to MVI, OSCSC Ltd.

Md.
3.6.20

Managing Director

